

## **SECTION 5**

### **5.10 LINE VALVES:**

Line valves are required approximately every 600 feet in all Distribution Systems receiving water from Denver Water. Where blocks exceed 600 feet in length, or if 2 or more hydrants are connected to the same main, additional line valves may be required in the middle of the block. Street intersections carrying heavy traffic, or containing major water Distribution Mains in both directions may require 4 valves, one on each extended property line. For a succession of short blocks perpendicular to the direction of major feed and without residential services between, several intersections may have the valve omitted in that direction but should retain the 600 feet interval requirement. A line valve is required between fire hydrants in commercial, residential and industrial areas.